

MATERIAL FLEXIBLE COPPER(30 SSG 20 NOS.) NO. OFF :- 4



ANDREW YULE & CO. LTD.  
ELECTRICAL DIVN. BRENTFORD UNIT  
KOLKATA - 700 088

FILE NO. 06\_2011\_052-055

SCALE : N.T.S.

TITLE :-


FLEXIBLE JUMPER DETAILS  
FOR 06/2011/052-055(A)

NAME	DATE
DRAWN <i>[Signature]</i>	8.5.12
CHECKED <i>[Signature]</i>	
APPROVED	
DRAWING NO. :-	A4-0891/052-055(A)
REV.	SHEET OF

REVISION BY DATE

THIS DRG. IS STRICTLY CONFIDENTIAL. IT IS THE EXCLUSIVE PROPERTY OF ANDREW YULE & CO. LTD. & MUST NOT BE COPIED OR REPRODUCED IN PART OR WHOLE WITHOUT COMPANY'S WRITTEN PERMISSION.







FOR TENDER  
PURPOSE ONLY

**ELECTRICAL SPECIFICATION IS:2099**

- 1) Rated Voltage ..... 1.1 kV.
- 2) Dry Power Frequency Withstand Voltage Test (one minute) ... 5 kV.
- 3) Maximum Current Capacity ..... 4000 Amps.

**NOTE :**

- 1) End Copper Palm will be electroplated 12 to 15 microns.
- 2) Electrolytic Copper with high Electrical Conductivity.
- 3) Colour brick red.
- 4) All dimensions are in mm.

	EPOXY RESIN CAST BUSHING			SIGN	DATE
	DRN.	Shailesh	26/12/2000		
	CHD.	Navneet	26/12/2000		
	APPD.	Prakash	26/12/2000		
			DRG.NO: EPB : B4 : 0027		
MANUFACTURER <b>BARODA BUSHINGS &amp; INSULATORS</b> "EPOXY HOUSE" 746/13 V.C.I.D.C. ESTATE, MAKARPURA, BANGALORE-560 010.			REV. 01		

ALL DIMENSIONS ARE IN mm

06/2011/052-055

NOT TO SCALE